

2024 Fire Inspection

Mr. Brian Mitchell
Ogdensburg Free Academy City School
1100 State Street
Ogdensburg, NY 13669

Dear Mr. Mitchell,

I am writing to inform you that I have successfully completed the fire inspections for all of the buildings within the district. It is now essential for the district to notify the public and the fire department as to the time and date of the inspection. All identified violations must be documented in the portal no later than August 1, 2024.

As a reminder, it's important to note that certain household items are not suitable for use within school premises. To address this concern, districts might consider reinforcing the policy among staff, urging them not to bring such store-bought items onto the school grounds. The district encompasses various decorative light strings, lamps, as well as carpets, warranting our attention. Also enclosed is a memo intended for all NY State school districts; the memo addresses many of these issues.

The violations are summarized below:

OFA High School:

Location	Code Reference #	Description	Date Corrected
Throughout	12-E-1	Improper UL Listing on String lights	

Kennedy School:

Location	Code Reference #	Description	Date Corrected
23, 24, 27, 42, 43, 54	9-D-1	Ceiling clearance of 24 inches is maintained	
33	14-A-2	Classroom visual panels covered.	
43	12-E-1	Covered Lights	
24, 33	14-A-2	Painted Ceiling Tiles	
Throughout	12-E-1	Improper UL Listing on String lights	

Madill School

Location	Code Reference #	Description	Date Corrected
Hallways	9-D-1	Ceiling clearance of 24 inches is maintained	

Throughout	12-E-1	Improper UL Listing on String lights	
Throughout	15-D-2	Curtains must meet criteria set forth in NFPA 701	

HS Garage 1: No violations were noted
HS Garage 2: No violations were noted
HS Garage 3: No violations were noted
HS Garage 4: No violations were noted
HS Garage 5 : No violations were noted
HS Garage 6: No violations were noted
Central Receiving: No violations were noted
Concession Stand: No violations were noted
Press Box: No violations were noted
Track Shed: No violations were noted
Snack Barn: No violations were noted
Golden Dome: No violations were noted
Metal Storage Shed Kennedy: No violations were noted
Madill Storage Building: No violations were noted
Bloomingtondale Storage Shed: No violations were noted

Thank you for your attention to these matters. If you have any questions or need further clarification, please do not hesitate to contact me.

Thank You,

Linda Shaw

Linda Shaw
 921 Miner Street Road
 Canton, NY 13617
 315-212-9479